

BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

# BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.

#### Listing Information

Vendor		Listing Status
Alerton - Honeywell 16201 25th Ave W Lynnwood WA 98087 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of July 2009	Revision 4 (135-2004)	February 2012

Product Name	Model Number(s)	Software Version
Visual Logic Display	VLD-362, VLD-362-W, VLD-362-FF, VLD-362-FF-W	5.10

#### **Device Profiles**

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

#### **BIBBs Supported**

	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
Data Sharing	WriteProperty-A	DS-WP-A
Data Sharing	WriteProperty-B	DS-WP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WritePropertyMultiple-B	DS-WPM-B

Scheduling	Weekly-Schedule-Internal-B	SCHED-WS-I-B
Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B

## **Object Type Support**

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Device	File	Multi-state Value
Program	Schedule	

### Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800

## Character Set Support

ANSI X3.4