



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.

Listing Information

Vendor		Listing Status
Alerton 6670 - 185 th Ave NE Redmond, WA 98053 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of June 2009	Revision 4 (135-2004)	June 2009

Product Name	Model Number	Software Version
Envision for BACtalk	EBT	2.6

Device Profiles

Profile	Model Numbers
BACnet Advanced Operator Workstation (B-AWS)	All Devices

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-A	DS-WPM-A
	WritePropertyMultiple-B	DS-WPM-B
	View-A	DS-V-A
	Advanced View-A	DS-AV-A
	Modify-A	DS-M-A
	Advanced Modify-A	DS-AM-A

Alarm and Event Notification	Notification-A	AE-N-A
	ACK-A	AE-ACK-A
	View Notifications-A	AE-VN-A
	Advanced View Notifications-A	AE-AVN-A
	View and Modify-A	AE-VM-A
	Advanced View and Modify-A	AE-AVM-A
	Alarm Summary View-A	AE-AS-A

Scheduling	View and Modify-A	SCHED-VM-A
	Advanced View and Modify-A	SCHED-AVM-A
	Weekly Schedule-A	SCHED-WS-A

Trending	Automated Trend Retrieval-A	T-ATR-A
	View-A	T-V-A
	Advanced View and Modify-A	T-AVM-A

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-A	DM-DOB-A
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-A	DM-DCC-A
	TimeSynchronization-A	DM-TS-A
	UTCTimeSynchronization-A	DM-UTC-A
	ReinitializeDevice-A	DM-RD-A
	Backup and Restore-A	DM-BR-A
	Object Creation and Deletion-A	DM-OCD-A
	Automatic Network Mapping-A	DM-ANM-A
	Automatic Device Mapping-A	DM-ADM-A
	Automatic Time Synchronization-A	DM-ATS-A
	Manual Time Synchronization-A	DM-MTS-A

Object Type Support

Analog Value	Binary Value	Device
--------------	--------------	--------

Data Link Layer Options

Media	Options
BACnet IP (Annex J)	
Ethernet, ISO 8802-3	

Character Set Support

ANSI X3.4
