



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

# BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

## Listing Information

|  |                          |                |
|--|--------------------------|----------------|
| Vendor   |                          | Listing Status |
| Delta Controls<br>17850 56 <sup>th</sup> Ave<br>Surrey, BC<br>Canada |                          | Listed Product |
| Test Requirements  | BACnet Protocol Revision | Date Tested    |
| Requirements as of August 2012                                       | Revision 12 (135-2010)   | June 2014      |

|              |              |                  |
|--------------|--------------|------------------|
| Product Name | Model Number | Software Version |
| enteliWEB    | eWEB         | 2.2              |

## Device Profiles

|                                     |               |
|-------------------------------------|---------------|
| Profile                             | Model Numbers |
| BACnet Operator Workstation (B-OWS) | eWEB          |

## BIBBs Supported

|              |                         |          |
|--------------|-------------------------|----------|
| Data Sharing | ReadProperty-A          | DS-RP-A  |
|              | ReadProperty-B          | DS-RP-B  |
|              | ReadPropertyMultiple-A  | DS-RPM-A |
|              | ReadPropertyMultiple-B  | DS-RPM-B |
|              | WriteProperty-A         | DS-WP-A  |
|              | WriteProperty-B         | DS-WP-B  |
|              | WritePropertyMultiple-A | DS-WPM-A |
|              | WritePropertyMultiple-B | DS-WPM-B |
|              | View-A                  | DS-V-A   |
|              | Advanced View-A         | DS-AV-A  |
|              | Modify-A                | DS-M-A   |

|                               |                             |           |
|-------------------------------|-----------------------------|-----------|
| Alarm and Event Notification  | Notification-A              | AE-N-A    |
|                               | ACK-A                       | AE-ACK-A  |
|                               | View and Modify-A           | AE-VM-A   |
|                               | Event Log-View-A            | AE-ELV-A  |
|                               | Event Log-View and Modify-A | AE-ELVM-A |
|                               | Alarm Summary-A             | AE-ASUM-A |
|                               | Enrollment Summary-A        | AE-ESUM-A |
|                               | Information-A               | AE-INFO-A |
|                               | Alarm Summary View-A        | AE-AS-A   |
|                               | View Notifications-A        | AE-VN-A   |
| Advanced View Notifications-A | AE-AVN-A                    |           |

|            |                              |            |
|------------|------------------------------|------------|
| Scheduling | Scheduling-A                 | SCHED-A    |
|            | Scheduling-View and Modify-A | SCHED-VM-A |
|            | Weekly Schedule-A            | SCHED-WS-A |

|          |  |          |
|----------|--|----------|
| Trending | Trending-View-A                        | T-V-A    |
|          | Viewing and Modifying Trends-A         | T-VMT-A  |
|          | Viewing and Modifying Multiple Value-A | T-VMMV-A |

|                               |                                |          |
|-------------------------------|--------------------------------|----------|
| Device and Network Management | Dynamic Device Binding-A       | DM-DDB-A |
|                               | Dynamic Device Binding-B       | DM-DDB-B |
|                               | Dynamic Object Binding-B       | DM-DOB-B |
|                               | DeviceCommunicationControl-B   | DM-DCC-B |
|                               | Automatic Network Mapping-A    | DM-ANM-A |
|                               | Automatic Device Mapping-A     | DM-ADM-A |
|                               | Time Synchronization-A         | DM-TS-A  |
|                               | UTC Time Synchronization-A     | DM-UTC-A |
|                               | Manual Time Synchronization-A  | DM-MTS-A |
|                               | Restart-B                      | DM-R-B   |
|                               | Object Creation and Deletion-B | DM-OCD-B |
| List Manipulation-B           | DM-LM-B                        |          |

## Object Type Support

|        |      |
|--------|------|
| Device | File |
|--------|------|

## Data Link Layer Options

| Media               | Options                    |
|---------------------|----------------------------|
| BACnet IP (Annex J) | Register as Foreign Device |
| Ethernet            |                            |

## Character Set Support

|                   |
|-------------------|
| ISO 10646 (UTF-8) |
|-------------------|