



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor		Listing Status
Douglas Lighting Controls 4455 Juneau Street Burnaby, BC V5C 4C4 Canada		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of <b>December 2011</b>	Revision 9	July 2012

Product Name	Model Number(s)	Software Version
MSTP-RS485 BACnet interface for WRS-2224 Scanner	WBI-2671	1.0.2

### Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

### BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	WriteProperty-B	DS-WP-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	ReinitializeDevice-B	DM-RD-B

### Object Type Support

Binary Input	Binary Value	
Device	Multi-state Input	Multi-state Value

## Data Link Layer Options

Media	Options
MS/TP Master	9600, 19200, 38400, 76800

## Character Set Support

ANSI X3.4 / UTF-8
-------------------