



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Labs Product Listing

*This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor		Listing Status
Honeywell International Inc. 1985 Douglas Drive North Golden Valley, MN 55422-3992 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of December 2011	Revision 9	December 2012

Product Name	Model Number	Software Version
ComfortPoint™ Open Plant Controller	CP-IPC	2.1.0.AZ2

### Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC)	CP-IPC

### BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-A	DS-WPM-A
	WritePropertyMultiple-B	DS-WPM-B
	COV-B	DS-COV-B

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	ACK-B	AE-ACK-B
	Alarm Summary-B	AE-ASUM-B
	Enrollment Summary-B	AE-ESUM-B
	Information B	AE-INFO-B

Scheduling	Internal-B	SCHED-I-B
	External-B	SCHED-E-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Automated Trend Retrieval-B	T-ATR-B

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTC TimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Restart-B	DM-R-B
	List Manipulation-B	DM-LM-B
Object Creation and Deletion-B	DM-OCD-B	

## Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Calendar	Device	File
Multi-State Value	Notification Class	Schedule
Structured View	Trend Log	

## Data Link Layer Options

Media	Options
BACnet IP (Annex J)	
MS/TP master	9600, 19200, 38400, 76800

## Networking Options

Networking Functionality	Media
Router	BACnet/IP (Annex J), MS/TP
Annex J BBMD	BACnet/IP

## Character Set Support

ANSI X3.4
ISO 10646 (UCS-2)