



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Labs Product Listing

*This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor Honeywell International Inc., ECC Buildings 1985 Douglas Drive North Dock 1 MN10-111B Golden Valley, MN 55422 USA		Listing Status  Listed Product
Test Requirements Requirements as of November 2014	BACnet Protocol Revision Revision 15	Date Tested October 2015

Product Name	Model Number	Software Version
Stryker BACnet VAV	CVB4024NS-VAV1/U	1.00 (build 12)
Stryker BACnet VAV	CVB4022AS-VAV1/U	1.00 (build 12)

### Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

### BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-B	DS-COV-B

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationsControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B

## Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	File
Program	Device	

## Data Link Layer Options

Media	Options
MS/TP	9600, 19200, 38400, 76800, 115200

## Character Set Support

ISO 10646 (UTF-8)
-------------------