



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of the BACnet Manufacturers Association (BMA). BTL is a registered trademark of the BMA.

BACnet Testing Labs Product Listing

This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BMA website.

Listing Information

Vendor		Listing Status
Honeywell Korea 56, Chaam-dong Cheonan-si, Chungcheongnam-do 330-200 Korea		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of July 2002	135-1995 rev 2	July 2002

Product Name	Model Number	Software Version
Excel Energy Manager(XEM)	SPS-COC-111-2-G	1

Product Name	Link to PICS on BMA Website
Excel Energy Manager(XEM)	

Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	SPS-COC-111-2-G

BIBBs Supported

Data Sharing	Read-Property-B	DS-RP-B
	Read-Property-Multiple-B	DS-RPM-B
	Write-Property-B	DS-WP-B
	Write-Property-Multiple-B	DS-WPM-B

Character Set Support

ANSI X3.4