



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of the BI.

## BACnet Testing Labs Product Listing

*This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor		Listing Status
Johnson Controls, Inc. 507 E. Michigan St. Milwaukee, WI 53202 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of <span style="color: green;">May 2005</span>	Revision 4 (135-2004)	September 2006

Product Name	Model Number	Software Version
Network Sensor	NS-xxA7xxx-x, NS-xxB7xxx-x, NS-xxC7xxx-x, NS-xxD7xxx-x, NS-xxN7xxx-x, NS-xxP7xxx-x	Rev 3.1 (Tested Rev 2.2)

## Device Profiles

Profile	Model Numbers
BACnet Smart Sensor (B-SS)	NS-xxA7xxx-x, NS-xxB7xxx-x, NS-xxC7xxx-x, NS-xxD7xxx-x, NS-xxN7xxx-x, NS-xxP7xxx-x

## BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	WriteProperty-B	DS-WP-B

Device and Network Management	ReinitializeDevice-B	DM-RD-B
-------------------------------	----------------------	---------

## Object Type Support

Analog Input	Analog Value	Binary Value
Multi-State Value	Device	

## Data Link Layer Options

Media	Options
MS/TP slave	9600, 19200, 38400, 76800

## Character Set Support

ANSI X3.4
-----------