



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of the BACnet Manufacturers Association (BMA). BTL is a registered trademark of the BMA.

BACnet Testing Labs Product Listing

This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BMA website.

Listing Information

Vendor		Listing Status
Lithonia Lighting 1 Lithonia Way Conyers, Georgia 30012-3957		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of May 2004	135-1995	May 2004

Product Name	Model Number	Software Version
Synergy MSTP	SYSC MSTP	Version 2.60

Product Name	Link to PICS on BMA Website
Synergy MSTP	http://www.bacnetassociation.org/BMAProductCatalog/Lithonia/PICS/SynergyPICS-MLX-MSTP.pdf

Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All Devices

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-A	DM-DOB-A
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B

--

ReinitializeDevice-B

DM-RD-B

Object Type Support

Analog Input	Analog Output	Analog Value
Device	Binary Input	Binary Output
Binary Value		

Data Link Layer Options

Media	Options
MS/TP master	9600,19200,38400,57600,115200

Character Set Support

ANSI X3.4
