



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.*

### Listing Information (BTL-30001)

Vendor		Listing Status
Opera Electronics Inc 697 Meloche St Dorval Quebec H9P2S4 Canada		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of October 2016	Revision 9	December, 2016

Product Name	Model Numbers	Software Version
Opera 6000	6000A, 6000B	2A28, 2B28

### Device Profiles

Profile	Model Numbers
BACnet Smart Sensor (B-SS)	All models

### BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	WriteProperty-B	DS-WP-B

Device Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B

### Object Type Support

Analog Value	Binary Input	Binary Output
Device		

## Data Link Layer Options

Media	Options
MS/TP Master	9600, 19200, 38400, 76800

## Character Set Support

ANSI X3.4	-- now includes UTF-8 encoded ISO 10646
-----------	---