



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor ARC Informatique 2 avenue de la Cristallerie 92310 SEVRES France		Listing Status  Listed Product
Test Requirements Requirements as of August 2012	BACnet Protocol Revision Revision 12 (135-2010)	Date Tested July 2015

Product Name PcVue	Model Number(s) PcVue	Software Version 11.2
-----------------------	--------------------------	--------------------------

### Device Profiles

Profile BACnet Operator Workstation (B-OWS)	Model Numbers PcVue models
--	-------------------------------

### BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-A	DS-WPM-A
	COV-A	DS-COV-A
	View-A	DS-V-A
	Modify-A	DS-M-A

Alarm and Event Management	Alarm and Event-Notification-A	AE-N-A
	Alarm and Event-ACK-A	AE-ACK-A
	Alarm and Event-Alarm Summary-A	AE-ASUM-A
	Alarm and Event-Enrollment Summary-A	AE-ESUM-A
	Alarm and Event-Information-A	AE-INFO-A
	Alarm and Event-Alarm Summary View-A	AE-AS-A
	Alarm and Event-View and Modify-A	AE-VM-A
	Alarm and Event-View Notifications-A	AE-VN-A

Scheduling	Scheduling-A	SCHED-A
	Scheduling-View and Modify-A	SCHED-VM-A

Trending	Trending-View-A	T-V-A
	Trending-View and Modify Trends-A	T-VMT-A

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	List Manipulation-A	DM-LM-A
	List Manipulation-B	DM-LM-B
	Automatic Network Mapping-A	DM-ANM-A
	Automatic Device Mapping-A	DM-ADM-A
	Time Synchronization-A	DM-TS-A
	UTC Time Synchronization-A	DM-UTC-A
	Manual Time Synchronization-A	DM-MTS-A

## Object Type Support

Device		
--------	--	--

## Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	Register as a Foreign Device

## Character Set Support

ISO 10646 (UTF-8)
-------------------