



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Labs Product Listing

This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.

Listing Information

| | | |
|--|--------------------------|----------------|
| Vendor | | Listing Status |
| Philips Teletrol 286 Commercial St. Manchester NH 03101 USA | | Listed Product |
| Test Requirements | BACnet Protocol Revision | Date Tested |
| Requirements as of July 2009 | Revision 4 (135-2004) | October 2009 |

| | | |
|--------------------------------------|--------------|------------------|
| Product Name | Model Number | Software Version |
| VZ7200 Zoning System Zone Thermostat | TZC-Z7200F-5 | 1.02.00 |

Device Profiles

| Profile | Model Numbers |
|--|---------------|
| BACnet Application Specific Controller (B-ASC) | TZC-Z7200F-5 |

BIBBs Supported

| | | |
|--------------|------------------------|----------|
| Data Sharing | ReadProperty-A | DS-RP-A |
| | ReadProperty-B | DS-RP-B |
| | ReadPropertyMultiple-B | DS-RPM-B |
| | WriteProperty-A | DS-WP-A |
| | WriteProperty-B | DS-WP-B |
| | COV-A | DS-COV-A |
| | COV-B | DS-COV-B |

| | | |
|-------------------------------|------------------------------|----------|
| Device and Network Management | Dynamic Device Binding-B | DM-DDB-B |
| | Dynamic Object Binding-B | DM-DOB-B |
| | DeviceCommunicationControl-B | DM-DCC-B |

Object Type Support

| | | |
|--------------|--------------|-------------------|
| Analog Input | Analog Value | Binary Input |
| Binary Value | Device | Multi-State Value |

Data Link Layer Options

| Media | Options |
|--------------|---------------------------|
| MS/TP master | 9600, 19200, 38400, 76800 |

Character Set Support

| |
|-----------|
| ANSI X3.4 |
|-----------|