



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.*

### Listing Information (BTL-24445)

Vendor		Listing Status
Schneider Electric Buildings and IT Business 800 Federal Street Andover MA 01810 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of November 2014	Revision 12 (135-2010)	September 2016

Product Name	Model Numbers	Software Version
SmartX Controller Automation Server	AS-P, AS-B	1.9

### Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC)	All models

### BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
COV-B	DS-COV-B	

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	ACK-B	AE-ACK-B
	Enrollment Summary-B	AE-ESUM-B
	Information-B	AE-INFO-B

Scheduling	Internal-B	SCHED-I-B
	External-B	SCHED-E-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Viewing and Modifying Trends External-B	T-VMT-E-B
	Automated Trend Retrieval-B	T-ATR-B

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-A	DM-TS-A
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-A	DM-UTC-A
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Object Creation and Deletion-B	DM-OCD-B
Automatic Time Synchronization-A	DM-ATS-A	

## Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Calendar	Device	Event Enrollment
File	Loop	Multi-state Input
Multi-state Output	Multi-state Value	Notification Class
Schedule	Trend Log	

## Data Link Layer Options

Media	Options
MS/TP Master	9600, 19200, 38400, 76800
BACnet/IP (Annex J)	BBMD, Register as Foreign Device

## Networking Options

Networking Functionality	Media
Router	MS/TP, BACnet/IP (Annex J)
BBMD	BACnet/IP (Annex J)

## Character Set Support

ISO 10646 (UTF-8)
ISO 8859-1
ISO 10646 (UCS-4)
ISO 10646 (UCS-2)