



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Labs Product Listing

*This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor		Listing Status
TAC, Systems Product Division 1354 Clifford Ave. Loves Park, IL 61111 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of <b>May 2005</b>	Revision 4 (135-2004)	February 2008

Product Name	Model Number	Software Version
I/A Series® MicroNet™ Plant Controller	MNB-1000	1.501 (tested 1.50)

## Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	MNB-1000

## BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
	COV-B	DS-COV-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-A	DM-DOB-A
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B

## Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Multi-State Value	Device	

## Data Link Layer Options

Media	Options
BACnet IP (Annex J)	
Ethernet, ISO 8802-3	
MS/TP master	9600, 19.2k, 38.4k, 76.8k

## Networking Options

Networking Functionality	Media
Router	BACnet/IP (Annex J), Ethernet, MS/TP
Annex J BBMD	BACnet/IP

## Character Set Support

ANSI X3.4
-----------