



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Labs Product Listing

This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.

Listing Information

Vendor		Listing Status
SE-Elektronik GmbH Eythstraße 16 73037 Göppingen, Germany		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of August 2012	Revision 12 (135-2010)	February 2015

Product Name	Model Number	Software Version
BACnet Building Controller E-DDC	E-DDC3.2, E-DDC5.0 H, E-DDC-B5.0, E-DDC-B6.0, E-DDC-B9.0, E-DDC3.3, E-DDC3.3S, E-DDC3.4S, E-DDC4.0, Router-GSM, Router-BC , GW-BC-SE, UGW	03.06.05

Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC)	All models

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-A	DS-WPM-A
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
	COV-B	DS-COV-B

Alarm and Event Notification	Notification-A	AE-N-A
	Notification Internal-B	AE-N-I-B
	Notification External-B	AE-N-E-B
	ACK-B	AE-ACK-B
	Alarm Summary-B	AE-ASUM-B
	Enrollment Summary-B	AE-ESUM-B
	Information B	AE-INFO-B
	Event Log-Internal-B	AE-EL-I-B
Event Log-External-B	AE-EL-E-B	

Scheduling	Internal-B	SCHED-I-B
	External-B	SCHED-E-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Viewing and Modifying Trends External-B	T-VMT-E-B
	Automated Trend Retrieval-B	T-ATR-B
	Viewing and Modifying Multiple Value-Internal-B	T-VMMV-I-B
	Viewing and Modifying Multiple Value-External-B	T-VMMV-E-B
	Automated Multiple Value Retrieval-B	T-AMVR-B

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-A	DM-DOB-A
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-A	DM-TS-A
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-A	DM-UTC-A
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Restart-B	DM-R-B
	List Manipulation-B	DM-LM-B
	Object Creation and Deletion-B	DM-OCD-B
	Manual Time Synchronization-A	DM-MTS-A
Automated Time Synchronization-A	DM-ATS-A	

Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Calendar	Command	Device
Event Enrollment	File	Group
Multi-State Input	Multi-State Output	Multi-State Value
Loop	Notification Class	Program
Averaging	Event Log	
Schedule	Trend Log	Trend Log Multiple
Bitstring Value	Date Value	Integer Value
Positive Integer Value	Time Value	Structured View

Data Link Layer Options

Media	Options
MS/TP Master	9600, 19200, 38400, 57600, 76800, 115200
BACnet IP (Annex J)	BBMD

Networking Options

Networking Functionality	Media
Routing	BACnet/IP-MS/TP
Annex J BBMD	BACnet/IP

Character Set Support

ANSI X3.4/UTF-8
ISO 10646 (UCS-2)
ISO 10646 (UCS-4)
ISO 8859-1