



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.

Listing Information (BTL-30245)

Vendor		Listing Status
Siemens Schweiz AG Gubelstrasse 22 6300 Zug Switzerland		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of November 2014	Revision 13	September 2017

Product Name	Model Numbers	Software Version
Desigo PXC3 Automation Stations	PXC3.E16A-100A, PXC3.E72-100A, PXC3.E72A-100A, PXC3.E75-100A, PXC3.E75A-100A	FW=01.21.31.131; WPC=1.4.130;SVS- 300.1:SBC=13.21

Device Profiles

Profile	Model Numbers
BACnet Advanced Application Controller (B-AAC)	All models

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-A	DS-WPM-A
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
	COV-B	DS-COV-B

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	ACK-B	AE-ACK-B
	Alarm Summary-B	AE-ASUM-B
	Enrollment Summary-B	AE-ESUM-B
	Information-B	AE-INFO-B
	Event Log - Internal - B	AE-EL-I-B

Scheduling	Internal-B	SCHED-I-B
------------	------------	-----------

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Automated Trend Retrieval-B	T-ATR-B

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Restart-B	DM-R-B
	List Manipulation-B	DM-LM-B

Object Type Support

Alert Enrollment	Analog Input	Analog Output
Analog Value	Binary Input	Binary Output
Binary Value	Calendar	Command
Device	Event Enrollment	Event Log
File	Loop	Multi-State Input
Multi-State Output	Multi-State Value	Notification Class
Positive Integer Value	Program	Schedule
Structured View	Trend Log	

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	Register as Foreign Device
MS/TP Master	9600, 19200, 38400, 76800, 115200

Character Set Support

ISO 10646 (UTF-8)
