



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor		Listing Status
Siemens Building Technologies 1000 Deerfield Pkwy Buffalo Grove, IL 60089 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of <a href="#">July 2009</a>	Revision 4 (135-2004)	October 2009

Product Name	Model Number	Software Version
TC Compact for BACnet MS/TP Networks	TC16.2-M.T TC24.2-M.T TC24.2-MR.T	3.2

## Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC)	All Devices

## BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
COV-B	DS-COV-B	

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	Notification External-B	AE-N-E-B
	ACK-B	AE-ACK-B
	Enrollment Summary-B	AE-ESUM-B
	Information B	AE-INFO-B

Scheduling	Internal-B	SCHEM-I-B
	External-B	SCHEM-E-B

Trending	Viewing and Modifying - Internal-B	T-VMT-I-B
	Viewing and Modifying - External-B	T-VMT-E-B
	Automated Trend Retrieval-B	T-ATR-B

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-A	DM-DOB-A
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	List Manipulation-B	DM-LM-B
	Object Creation and Deletion-B	DM-OCD-B

## Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Calendar	Command	Device
Event Enrollment	File	Multi-State Output
Multi-State Value	Notification Class	
Schedule	Trend Log	

## Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800, 115200

## Character Set Support

ANSI X3.4
-----------