



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Labs Product Listing

*This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor		Listing Status
TRIACTA Power Technologies Inc. 130 Industrial Avenue, Suite 100 Carleton Place ON K7C 3T2 Canada		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of <b>August 2012</b>	Revision 10	October 2012

Product Name	Model Number	Software Version
4000/6000	POWERHAWK 6312 HIGH DENSITY METER 120V/240V/277V-60Hz (100-300V Ref)	1
	POWERHAWK 6312 HIGH DENSITY METER 230V-50HZ (100-300V Ref)	
	POWERHAWK 6212 POWER MONITOR 120V/240V/277V-60Hz (100-300V Ref)	
	POWERHAWK 6212 POWER MONITOR 230V-50HZ (100-300V Ref)	
	POWERHAWK 6412 HIGH DENSITY METER 120V/240V/277V-60Hz (100-300V Ref)	
	POWERHAWK 6412 HIGH DENSITY METER 230V-50HZ (100-300V Ref)	
	POWERHAWK 4206 MULTI-POINT BUILDING AUTOMATION METER 120V/240V/277V-60Hz (100-300V Ref)	
	POWERHAWK 4206 MULTI-POINT BUILDING AUTOMATION METER 230V-50Hz (100-300V Ref)	
	POWERHAWK 4306 MULTI-POINT BUILDING AUTOMATION METER 120V/240V/277V-60Hz (100-300V Ref)	
	POWERHAWK 4306 MULTI-POINT BUILDING AUTOMATION METER 230V-50Hz (100-300V Ref) 1	
	POWERHAWK 4224 MULTI-POINT BUILDING AUTOMATION METER 120V/240V/277V-60Hz (100-300V Ref)	
	POWERHAWK 4224 MULTI-POINT BUILDING AUTOMATION METER	

<p>230V-50Hz (100-300V Ref)</p> <p>POWERHAWK 4324 MULTI-POINT BUILDING AUTOMATION METER 120V/240V/277V-60Hz (100-300V Ref) POWERHAWK 4324 MULTI-POINT BUILDING AUTOMATION METER 230V-50Hz (100-300V Ref)</p> <p>POWERHAWK 6103 MULTI-POINT METER 120V/240V/277V 60Hz (100-300V Ref) POWERHAWK 6103 MULTI-POINT METER 230V 50HZ (100-300V Ref)</p> <p>POWERHAWK 6112 HIGH DENSITY METER 120V/240V/277V-60Hz (100-300V Ref) POWERHAWK 6112 HIGH DENSITY METER 230V 50HZ (100-300V Ref)</p> <p>POWERHAWK 4106 MULTI-POINT BUILDING AUTOMATION METER 120V/240V/277V-60Hz (100-300V Ref) POWERHAWK 4106 MULTI-POINT BUILDING AUTOMATION METER 230V-50Hz (100-300V Ref)</p> <p>POWERHAWK 4124 MULTI-POINT BUILDING AUTOMATION METER 120V/240V/277V-60Hz (100-300V Ref) POWERHAWK 4124 MULTI-POINT BUILDING AUTOMATION METER 230V-50Hz (100-300V Ref)</p>	
--	--

## Device Profiles

Profile	Model Numbers
BACnet Smart Actuator (B-SA)	All models

## BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B

## Object Type Support

Analog Input	Device

## Data Link Layer Options

Media	Options
BACnet IP (Annex J)	Register as Foreign Device

# Character Set Support

UTF-8 / ANSI X3.4
-------------------