



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor Vertiv 1050 Dearborn Dr Columbus, OH 43085 USA		Listing Status  Listed Product
Test Requirements Requirements as of November 2014	BACnet Protocol Revision Revision 9	Date Tested September 2015

Product Name Liebert® IntelliSlot® Unity Card	Model Number IS-UNITY-DP	Software Version 6.0
--	-----------------------------	-------------------------

### Device Profiles

Profile BACnet Smart Actuator (B-SA)	Model Numbers All models
---	-----------------------------

### BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	WriteProperty-B	DS-WP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-B	DS-COV-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	TimeSynchronization-B	DM-TS-B
	UTC TimeSynchronization-B	DM-UTC-B

## Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Multi-state Input	Multi-state Output	Multi-state Value
Device		

## Data Link Layer Options

Media	Options
BACnet/IP	Register as a Foreign Device
MS/TP master	9600, 19200, 38400, 57600, 76800, 115200

## Character Set Support

ANSI X3.4
-----------