



Date: November 26, 2009
Vendor Name: Delta Controls Inc.
Product Name: ORCAview
Product Model Number: DOW-340
Product Version: 3.40
BACnet Protocol Revision: 6

Product Description:

ORCAview is an industry leading operator workstation software package that combines an intuitive graphical user interface with powerful, easy-to-use facility management tools. Custom graphics allow facility managers to operate their buildings easily and efficiently by monitoring equipment status, alarms, and adjusting setpoints and schedules. Professional reports can be created for tenant billing and door access activity using powerful built-in reporting tools. Alarms can be E-mailed or paged to service personnel with the built-in Event Management System. The system language can be changed on-the-fly. Historical data for thousands of trend logs and events can be archived and retrieved with the optional SQL server based Delta Historian. Building system information can be integrated with business-level products using the optional Delta ODBC Driver.

BACnet devices from any vendor are automatically detected and integrated into the software, giving facility managers a single-seat of operation for all their systems. ORCAview uses BACnet IP to communicate over wide area networks including the Internet or intranets to any building or site. BACnet over Ethernet and BACnet MS/TP are used to communicate to local area networks. BACnet PTP may be used to connect to any Delta Systems Controller either directly or via modem for remote site-wide access.

BACnet Standardized Device Profile (Annex L):

- BACnet Advanced Operator Workstation (B-AWS)
- BACnet Life-safety Workstation (B-LSWS)
- BACnet Operator Workstation (B-OWS)
- BACnet Building Controller (B-BC)
- BACnet Advanced Application Controller (B-AAC)
- BACnet Application Specific Controller (B-ASC)
- BACnet Smart Sensor (B-SS)
- BACnet Smart Actuator (B-SA)

Data Sharing-WritePropertyMultiple-A (DS-WPM-A)	<input checked="" type="checkbox"/>
Data Sharing-WritePropertyMultiple-B (DS-WPM-B)	<input checked="" type="checkbox"/>
Data Sharing-COV-A (DS-COV-A)	<input checked="" type="checkbox"/>
Data Sharing-COV-B (DS-COV-B)	<input checked="" type="checkbox"/>
Data Sharing-COVP-A (DS-COVP-A)	<input type="checkbox"/>
Data Sharing-COVP-B (DS-COVP-B)	<input type="checkbox"/>
Data Sharing-COV-Unsolicited-A (DS-COVU-A)	<input checked="" type="checkbox"/>
Data Sharing-COV-Unsolicited-B (DS-COVU-B)	<input checked="" type="checkbox"/>
Data Sharing-View-A (DS-V-A)	<input checked="" type="checkbox"/>
Data Sharing-Advanced View-A (DS-AV-A)	<input checked="" type="checkbox"/>
Data Sharing-Modify-A (DS-M-A)	<input checked="" type="checkbox"/>
Data Sharing-Advanced Modify-A (DS-AM-A)	<input checked="" type="checkbox"/>
Scheduling	
Scheduling-A (SCHED-A)	<input checked="" type="checkbox"/>
Scheduling-Internal-B (SCHED-I-B)	<input checked="" type="checkbox"/>
Scheduling-External-A (SCHED-E-B)	<input checked="" type="checkbox"/>
Scheduling-View Modify-A (SCH-VM-A)	<input checked="" type="checkbox"/>
Scheduling-Advanced View Modify-A (SCH-AVM-A)	<input checked="" type="checkbox"/>
Scheduling-Weekly Schedule-A (SCH-WS-A)	<input checked="" type="checkbox"/>
Scheduling-Weekly Schedule Internal-B (SCH-WS-I-B)	<input checked="" type="checkbox"/>
Scheduling-Readable-B (SCH-R-B)	<input type="checkbox"/>
Trending	
Trending-View - A (T-V-A)	<input checked="" type="checkbox"/>
Trending-Viewing and Modifying Trends-A (T-VMT-A)	<input checked="" type="checkbox"/>
Trending-Viewing and Modifying Trends-Internal-B (T-VMT-I-B)	<input checked="" type="checkbox"/>
Trending-Viewing and Modifying Trends-External-B (T-VMT-E-B)	<input checked="" type="checkbox"/>
Trending-Automated Trend Retrieval-A (T-ATR-A)	<input checked="" type="checkbox"/>
Trending-Automated Trend Retrieval-B (T-ATR-B)	<input checked="" type="checkbox"/>
Trending-Archiving-A (T-A-A)	<input checked="" type="checkbox"/>
Network Management	
Network Management-Connection Establishment-A (NM-CE-A)	<input checked="" type="checkbox"/>
Network Management-Connection Establishment-B (NM-CE-B)	<input checked="" type="checkbox"/>
Network Management-Router Configuration-A (NM-RC-A)	<input type="checkbox"/>
Network Management-Router Configuration-B (NM-RC-B)	<input type="checkbox"/>
Alarm and Event Management	
Alarm and Event-Notification-A (AE-N-A)	<input checked="" type="checkbox"/>
Alarm and Event-Notification Internal-B (AE-N-I-B)	<input checked="" type="checkbox"/>
Alarm and Event-Notification External-A (AE-N-E-B)	<input checked="" type="checkbox"/>
Alarm and Event-ACK-A (AE-ACK-A)	<input checked="" type="checkbox"/>
Alarm and Event-ACK-B (AE-ACK-B)	<input checked="" type="checkbox"/>
Alarm and Event-Alarm Summary-A (AE-ASUM-A)	<input checked="" type="checkbox"/>
Alarm and Event-Alarm Summary-B (AE-ASUM-B)	<input checked="" type="checkbox"/>

Subject to Change

Page 2 of 6

Device Management-Dynamic Device Binding-B (DM-DDB-B)	<input checked="" type="checkbox"/>
Device Management-Dynamic Object Binding-A (DM-DOB-A)	<input checked="" type="checkbox"/>
Device Management-Dynamic Object Binding-B (DM-DOB-B)	<input checked="" type="checkbox"/>
Device Management-DeviceCommunicationControl-A (DM-DCC-A)	<input checked="" type="checkbox"/>
Device Management-DeviceCommunicationControl-B (DM-DCC-B)	<input checked="" type="checkbox"/>
Device Management-Private Transfer-A (DM-PT-A)	<input checked="" type="checkbox"/>
Device Management-Private Transfer-B (DM-PT-B)	<input checked="" type="checkbox"/>
Device Management-Text Message-A (DM-TM-A)	<input type="checkbox"/>
Device Management-Text Message-B (DM-TM-B)	<input checked="" type="checkbox"/>
Device Management-TimeSynchronization-A (DM-TS-A)	<input checked="" type="checkbox"/>
Device Management-TimeSynchronization-B (DM-TS-B)	<input type="checkbox"/>
Device Management-Automatic Time Synchronization-A (DM-ATS-A)	<input checked="" type="checkbox"/>
Device Management-Manual Time Synchronization-A (DM-MTS-A)	<input checked="" type="checkbox"/>
Device Management-UTCTimeSynchronization-A (DM-UTC-A)	<input checked="" type="checkbox"/>
Device Management-UTCTimeSynchronization-B (DM-UTC-B)	<input checked="" type="checkbox"/>
Device Management-ReinitializeDevice-A (DM-RD-A)	<input checked="" type="checkbox"/>
Device Management-ReinitializeDevice-B (DM-RD-B)	<input type="checkbox"/>
Device Management-Backup and Restore-A (DM-BR-A)	<input checked="" type="checkbox"/>
Device Management-Backup and Restore-B (DM-BR-B)	<input type="checkbox"/>
Device Management-List Manipulation-A (DM-LM-A)	<input checked="" type="checkbox"/>
Device Management-List Manipulation-B (DM-LM-B)	<input checked="" type="checkbox"/>
Device Management-Object Creation and Deletion-A (DM-OCD-A)	<input checked="" type="checkbox"/>
Device Management-Object Creation and Deletion-B (DM-OCD-B)	<input checked="" type="checkbox"/>
Device Management-Virtual Terminal-A (DM-VT-A)	<input type="checkbox"/>
Device Management-Virtual Terminal-B (DM-VT-B)	<input type="checkbox"/>
Device Management-Automatic Network Mapping-A (DM-ANM-A)	<input checked="" type="checkbox"/>
Device Management-Automatic Device Mapping-A (DM-ADM-A)	<input checked="" type="checkbox"/>

Segmentation Capability:

Segmented Requests Supported Window Size: 2
 Segmented Responses Supported Window Size: 2

Standard Object Types Supported:

Object-Type	Supported	Dynamically Creatable	Dynamically Deletable	Optional Properties Supported	Writable Properties
Accumulator	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		

Analog Value	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Description, Reliability, COV Increment	Object Name, Description, Present Value, Units, Reliability, COV Increment, Out of Service
Averaging	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Binary Input	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Description, Device Type, Reliability, Active Text, Inactive Text, COS Time, COS Count, COS Time, Reset	Object Name, Description, Present Value, Reliability, Polarity, Change of State Count, Out of Service
Binary Output	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Description, Device Type, Reliability, Active Text, Inactive Text, COS Time, COS Count, COS Time Reset, Min On Time, Min Off Time	Object Name, Description, Present Value, Reliability, Polarity, Change of State Count, Relinquish Default, Min On Time, Min Off Time, Out of Service
Binary Value	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Description, Reliability, Active Text, Inactive Text	Object Name, Description, Present Value, Out of Service, Reliability
Calendar	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Description	Object Name, Description, Present Value, Date List
Command	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Device	YES	N/A	N/A	Description, Location, APDU Seg Timeout, Time Synch Recipients, Max Segments Accepted, Max Master, Max Info Frames, Local Time, Local Date, UTC Offset, DST Status, Configuration Files, Last Restore Time, Backup Failure Timeout, Active COV Subscriptions	Object Name, Description, Location, Time Synch Recipients, UTC Offset, Backup Failure Timeout
Event Enrollment	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Description, Notification Class	Object Name, Description, Event Type, Event Parameters, Object Property Reference, Event Enable, Notification Class
File	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Description	Object Name, Description, File Type, File Size, Archive, Read Only

				Derivative Units, Bias, Maximum Output, Minimum Output, COV Increment	Constant, Integral Constant, Derivative Constant, Bias, Priority For Writing, COV Increment
Multi-state Input	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Multi-state Output	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Multi-state Value	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Description, Reliability, State Text	Object Name, Description, Present Value, Reliability, Out Of Service
Notification Class	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Description	Object Name, Description, Priority, Ack Required, Recipient List
Program	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Description, Reliability, Reason for Halt, Description of Hal	Object Name, Description, Present Value, Reliability, Program Change,
Pulse Converter	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Schedule	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Description, Schedule Exceptions	Object Name, Description, Present Value, Effective Period, Weekly Schedule, Exception Schedule, List of Object Property References, Priority for Writing
Structured View	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Trend Log	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Description, Start Time, Stop Time, Log Device Object Prop, Log Interval, COV Resubscription Interval, Notification Threshold, Records Since Notification, Notification Class, Event Enable, Acked Transitions, Notify Type, Event Time Stamps	Object Name, Description, Log Enable, Start Time, Stop Time, Log Device Object Prop, Log Interval, COV_Resubscription Interval, Stop When Full, Buffer Size, Record Count, Notification Threshold, Notification Class, Event Enable,
Proprietary	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		

Data Link Layer Options:

- BACnet IP, (Annex J)
- BACnet IP, (Annex J), Foreign Device
- ISO 8802-3, Ethernet (Clause 7) (10Base2, 10Base5, 10BaseT, Fiber)

Subject to Change

Page 5 of 6

Networking Options:

- Router
- Annex H, BACnet Tunnelling
- BACnet/IP Broadcast Management Device (BBMD)
 - Does the BBMD support registrations by Foreign Devices?

Character Sets Supported:

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

- ANSI X3.4
- IBM/Microsoft DBCS
- JIS C 6226
- ISO 10646 (ICS-4)
- ISO 10646 (UCS2)
- ISO 8859-1

If this product is a communication gateway, describe the types of non-BACnet equipment/networks(s) that the gateway supports:

Not applicable.