## **BACnet Protocol Implementation Conformance Statement**

Date: <u>April 1, 2016</u> Vendor Name: <u>Honeywell International, Inc</u> Product Name: <u>HT9631D Series Driver</u> Product Model Numbers: <u>HT9631D3100</u>

Application Software Version: 1.00 (build 01) Firmware Revision: 1.00 (build 01) BACnet Protocol Revision: 4

#### **Product Description:**

The HT9631D Series Driver is designed for application of fan coil system of BACnet MS/TP communication. And it provides inputs/outputs and communication interface for thermostats.

### **BACnet Standardized Device Profile (Annex L):**

BACnet Operator Workstation (B-OWS)
 BACnet Building Controller (B-BC)
 BACnet Advanced Application Controller (B-AAC)
 X BACnet Application Specific Controller (B-ASC)
 BACnet Smart Sensor (B-SS)
 BACnet Smart Actuator (B-SA)

### List all BACnet Interoperability Building Blocks Supported (Annex K):

BIBB	Service	Initiates	Responds to
DS-RP-A/B	ReadProperty		Х
DS-RPM-B	ReadPropertyMultiple		Х
DS-WP-A/B	WriteProperty		Х
DS-WPM-B	WritePropertyMultiple		Х
DM-DDB-A/B	Who-Is		Х
DM-DDB-A/B	I-Am	Х	Х
DM-DOB-B	Who-Has		Х
DM-DOB-B	I-Have	Х	
DM-DCC-B	DeviceCommunicationControl		Х

### **Segmentation Capability:**

□ Segmented requests supported Window Size \_\_\_\_\_ □ Segmented responses supported Window Size \_\_\_\_\_

# Honeywell

# **Standard Object Types Supported:**

An object type is supported if it may be present in the device. For each standard Object Type supported provide the following data:

- 1) Whether objects of this type are dynamically creatable using the CreateObject service
- 2) Whether objects of this type are dynamically deletable using the DeleteObject service
- 3) List of the optional properties supported
- 4) List of all properties that are writable where not otherwise required by this standard
- 5) List of proprietary properties and for each its property identifier, datatype, and meaning
- 6) List of any property range restrictions

Note: none of the object types listed in this section is dynamically creatable or dynamically deletable. Note: the BACnet conformance codes are as follows:

- O Optional (may be required under some conditions)
- R Required, but not required to be writable (may be required to be writable under some conditions)
- W Not only required, but also required to be writable

The following codes are used in this document to describe how the properties are implemented:

- R/O Read-only
- R/O=value Implemented as a read-only with the indicated value

### **Device Object**

Property	BACnet Conf Code	Implementation
Object_Identifier	R	R/W
Object_Name	R	R/W
Object_Type	R	R/O="device"
System_Status	R	R/O="operational"
Vendor_Name	R	R/O
Vendor_Identifier	R	R/O
Model_Name	R	R/O
Firmware_Revision	R	R/O
Application_Software_Version	R	R/O
Protocol_Version	R	R/O=1
Protocol_Revision	R	R/O=4
Protocol_Services_Supported	R	R/O
Protocol_Object_Types_Supported	R	R/O
Object_List	R	R/O
Max_APDU_Length_Accepted	R	R/O=206
Segmentation_Supported	R	R/O="none"
Local_Time	0	R/O
Local_Date	0	R/O
UTC_Offset	0	R/W
Daylight_Savings_Status	0	R/O
APDU_Timeout	R	R/W
Number_Of_APDU_Retries	R	R/W
Device_Address_Binding	R	R/O=empty list
Database_Revision	R	R/O
Max_Master	0	R/W
Max_Info_Frames	0	R/W
location	0	R/W
description	0	R/W

# Honeywell Analog Input

Property	BACnet Conf Code	Implementation
Object_Identifier	R	R/O
Object_Name	R	R/O
Object_Type	R	R/O="analog-input"
Present_Value	R	R/O
Status_Flags	R	R/O="all normal"
Event_State	R	R/O="normal"
Out_Of_Service	R	R/O=FALSE
Units	R	R/O

# **Analog Value**

Property	BACnet Conf Code	Implementation
Object_Identifier	R	R/O
Object_Name	R	R/O
Object_Type	R	R/O="analog-value"
Present_Value	R	R/W
Status_Flags	R	R/O="all normal"
Event_State	R	R/O="normal"
Out_Of_Service	R	R/O=FALSE
Units	R	R/O

# **Binary Output**

Property	BACnet Conf Code	Implementation
Object_Identifier	R	R/O
Object_Name	R	R/O
Object_Type	R	R/O="binary-output"
Present_Value	W	R/W
Status_Flags	R	R/O="all normal"
Event_State	R	R/O="normal"
Out_Of_Service	R	R/O=FALSE
Polarity	R	R/O
Priority_Array	R	R/O
Relinquish_Default	R	R/W

# Honeywell

# **Data Link Layer Options:**

BACnet IP, (Annex J)
BACnet IP, (Annex J), Foreign Device
ISO 8802-3, Ethernet (Clause 7)
ANSI/ATA 878.1, 2.5 Mb. ARCNET (Clause 8)
ANSI/ATA 878.1, RS-485 ARCNET (Clause 8), baud rate(s)
X MS/TP master (Clause 9), baud rate(s): <u>9600, 19200, 38400, 76800</u>
MS/TP slave (Clause 9), baud rate(s): <u>9600, 19200, 38400, 76800</u>
MS/TP slave (Clause 9), baud rate(s): <u>9600, 19200, 38400, 76800</u>
MS/TP slave (Clause 9), baud rate(s): <u>9600, 19200, 38400, 76800</u>
MS/TP slave (Clause 9), baud rate(s): <u>9600, 19200, 38400, 76800</u>
MS/TP slave (Clause 9), baud rate(s): <u>9600, 19200, 38400, 76800</u>
MS/TP slave (Clause 10), baud rate(s): <u>9600, 19200, 38400, 76800</u>
Doint-To-Point, EIA 232 (Clause 10), baud rate(s): <u>9600, 19200, </u>

### **Device Address Binding:**

Is static device binding supported? (This is currently necessary for two-way communication with MS/TP slaves and certain other devices.)  $\Box$ Yes X No

#### **Networking Options:**

Router, Clause 6 - List all routing configurations, e.g., ARCNET-Ethernet, Ethernet-MS/TP, etc.
 Annex H, BACnet Tunneling Router over IP
 RACnet (ID President Management During (RDMD)

□ BACnet/IP Broadcast Management Device (BBMD) Does the BBMD support registrations by Foreign Devices? □ Yes □ No

### **Character Sets Supported:**

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

X ANSI X3.4 $\Box$  IBM<sup>TM</sup>/Microsoft<sup>TM</sup> DBCS $\Box$  ISO 8859-1X ISO 10646 (UCS-2) $\Box$  ISO 10646 (UCS-4) $\Box$  JIS C 6226

# If this product is a communication gateway, describe the types of non-BACnet equipment/networks(s) that the gateway supports: