



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of the BACnet Manufacturers Association (BMA). BTL is a registered trademark of the BMA.

BACnet Testing Labs Product Listing

This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BMA website.

Listing Information

Vendor		Listing Status
Siemens Building Technologies – BAU NA 1000 Deerfield Parkway Buffalo Grove, Illinois USA 60089		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of August 2005	135-2001b	August 2005

Product Name	Model Number	Software Version
BACnet Terminal Equipment Controller - VAV	550-788A	Rev. 1.1

Product Name	Link to PICS on BMA Website
BACnet Terminal Equipment Controller - VAV	http://bacnetassociation.org/btl/Listings/Siemens/Siemens.htm

Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All Devices

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	WriteProperty-B	DS-WP-B
	ReadPropertyMultiple-B	DS-RPM-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B

Object Type Support

Analog Input	Analog Output	Binary Input
Binary Output	Device	

Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800
MS/TP slave	9600, 19200, 38400, 76800

Character Set Support

ANSI X3.4
