



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.

Listing Information (BTL-30554)

Vendor AAON Parkville 8500 NW River Park Drive Parkville, MO 64152 USA		Listing Status Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of November 2014	Revision 12 (135-2010)	December 2017

Product Name	Model Numbers	Software Version
VCCX2 Controller	ASM01698	FW 1.23
LF Chiller Controller	ASM02437	FW 1.23
DX Chiller Controller	ASM02317	FW 1.23
AZ3 Main Controller	ASM02450	FW 1.23
AZ3 VAV/Zone BACnet P.D. Controller	ASM02424	FW 1.23
AZ3 VAV/Zone BACnet P.I. Controller	ASM02425	FW 1.23
VAV/Zone BACnet P.D. Controller	ASM02426	FW 1.23
VAV/Zone BACnet P.I. Controller	ASM02427	FW 1.23

Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B

Device Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B

Object Type Support

Analog Input	Analog Value	Binary Input
Binary Value	Device	Multi-State Input
Multi-State Value		

Data Link Layer Options

Media	Options
MS/TP Master	9600, 19200, 38400, 57600, 76800

Character Set Support

ISO 10646 (UTF-8)
