



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.*

### Listing Information (BTL-24436)

|  |                          |                |
|--|--------------------------|----------------|
| Vendor   |                          | Listing Status |
| AB Industrietechnik SRL<br>Via Julius Durst 70<br>I-39042 Bressanone (BZ)<br>ITALY |                          | Listed Product |
| Test Requirements  | BACnet Protocol Revision | Date Tested    |
| Requirements as of November 2014   | Revision 12 (135-2010)   | July 2016      |

|                      |               |                  |
|----------------------|---------------|------------------|
| Product Name         | Model Numbers | Software Version |
| Evolution Controller | TH-*          | 3.2.0.6          |

### Device Profiles

|  |               |
|--|---------------|
| Profile  | Model Numbers |
| BACnet Application Specific Controller (B-ASC) | All models    |

### BIBBs Supported

|              |                        |          |
|--------------|------------------------|----------|
| Data Sharing | ReadProperty-B         | DS-RP-B  |
|              | ReadPropertyMultiple-B | DS-RPM-B |
|              | WriteProperty-B        | DS-WP-B  |

|                   |                              |          |
|-------------------|------------------------------|----------|
| Device Management | Dynamic Device Binding-B     | DM-DDB-B |
|                   | Dynamic Object Binding-B     | DM-DOB-B |
|                   | DeviceCommunicationControl-B | DM-DCC-B |
|                   | TimeSynchronization-B        | DM-TS-B  |

### Object Type Support

|              |              |                   |
|--------------|--------------|-------------------|
| Analog Input | Analog Value | Binary Input      |
| Binary Value | Device       | Multi-state Value |

## Data Link Layer Options

| Media                  | Options                   |
|------------------------|---------------------------|
| MS/TP Master and Slave | 9600, 19200, 38400, 76800 |

## Character Set Support

|                   |
|-------------------|
| ISO 10646 (UTF-8) |
|-------------------|