



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

# BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

## Listing Information

Vendor		Listing Status
Airtek International Inc. 19 F., Suite 4, No.77, Sec. 1, Xintai 5th Rd., Xizhi Dist., New Taipei City, 22101 Taiwan		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of August 2012	Revision 7 (135-2008)	December 2013

Product Name	Model Number	Software Version
BACnet Advanced Operator Workstation	BACsoft - AWS	2.58

## Device Profiles

Profile	Model Numbers
BACnet Advanced Operator Workstation (B-AWS)	BACsoft - AWS

## BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-A	DS-WPM-A
	WritePropertyMultiple-B	DS-WPM-B
	View-A	DS-V-A
	Advanced View-A	DS-AV-A
	Modify-A	DS-M-A
	Advanced Modify-A	DS-AM-A

Alarm and Event Notification	Notification-A	AE-N-A
	ACK-A	AE-ACK-A
	Alarm Summary-A	AE-ASUM-A
	Enrollment Summary-A	AE-ESUM-A
	Information-A	AE-INFO-A
	View Notifications-A	AE-VN-A
	Advanced View Notifications-A	AE-AVN-A
	View and Modify-A	AE-VM-A
	Advanced View and Modify-A	AE-AVM-A
	Event Log View-A	AE-ELV-A
	Event Log View and Modify-A	AE-ELVM-A
Alarm Summary View-A	AE-AS-A	

Scheduling	Scheduling-A	SCHED-A
	View and Modify-A	SCHED-VM-A
	Advanced View and Modify-A	SCHED-AVM-A
	Weekly Schedule-A	SCHED-WS-A

Trending	Viewing and Modifying Trends-A	T-VMT-A
	View-A	T-V-A
	Advanced View and Modify-A	T-AVM-A
	Automated Trend Retrieval-A	T-ATR-A

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-A	DM-DCC-A
	TimeSynchronization-A	DM-TS-A
	UTCTimeSynchronization-A	DM-UTC-A
	ReinitializeDevice-A	DM-RD-A
	Backup and Restore-A	DM-BR-A
	Automatic Network Mapping-A	DM-ANM-A
	Automatic Device Mapping-A	DM-ADM-A
	Manual Time Synchronization-A	DM-MTS-A
	Automatic Time Synchronization-A	DM-ATS-A
	Object Creation and Deletion-A	DM-OCD-A

## Object Type Support

Analog Value	Binary Value	Device
--------------	--------------	--------

## Data Link Layer Options

Media	Options
BACnet IP (Annex J)	Register as Foreign Device
Ethernet	

## Character Set Support

ANSI X3.4/UTF-8
-----------------