



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor Alerton/Honeywell 16201 25th Ave W Lynnwood WA 98087 USA		Listing Status  Listed Product
Test Requirements Requirements as of July 2009	BACnet Protocol Revision Revision 4 (135-2004)	Date Tested July 2011

Product Name MS/TP Microset II	Model Number(s) MS/TP MS-II	Software Version 5.00
-----------------------------------	--------------------------------	--------------------------

### Device Profiles

Profile BACnet Application Specific Controller (B-ASC)	Model Numbers MS-II
---	------------------------

### BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-B	DS-COV-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B

	ReinitializeDevice-B	DM-RD-B
--	----------------------	---------

### Object Type Support

Analog Input	Analog Value	Binary Value
Device	File	Program

### Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800

### Character Set Support

ANSI X3.4
-----------