



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor Alerton 16201 25th Ave W Lynnwood, WA 98087 USA		Listing Status  Listed Product
Test Requirements Requirements as of September 2014	BACnet Protocol Revision Revision 15	Date Tested May 2015

Product Name Ascent Control Module (ACM)	Model Number ACM-GC	Software Version 1.5.x
---	------------------------	---------------------------

### Device Profiles

Profile BACnet Building Controller (B-BC)	Model Numbers All models
--	-----------------------------

### BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
COV-B	DS-COV-B	

	Alarm and Event-Notification Internal-B	AE-N-I-B
--	---	----------

Alarm and Event Management	Alarm and Event-Notification External-B	AE-N-E-B
	Alarm and Event-ACK-B	AE-ACK-B
	Alarm and Event-Alarm Summary-B	AE-ASUM-B
	Alarm and Event-Enrollment Summary-B	AE-ESUM-B
	Alarm and Event-Information-B	AE-INFO-B

Scheduling	Scheduling Internal-B	SCHED-I-B
	Scheduling External-B	SCHED-E-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Viewing and Modifying Trends External-B	T-VMT-E-B
	Automated Trend Retrieval-B	T-ATR-B

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTC TimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Object Creation and Deletion-B	DM-OCD-B

## Object Type Support

Analog Input	Analog Value	
Binary Input	Binary Value	
Calendar	Device	Event Enrollment
File	Multi-state Value	Notification Class
Program	Schedule	Trend Log

## Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800, 115200
BACnet/IP (Annex J)	BBMD
Ethernet	

## Character Set Support

ISO 10646 (UTF-8)
-------------------

## Networking Options

Networking Functionality	Media
Router	BACnet/IP (Annex J), MS/TP, Ethernet