



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-30776)

Vendor		Listing Status
ARC Informatique 2 Avenue de la Cristallerie 92310 Sèvres France		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of February 2021	Revision 12 (135-2010)	December 2015

Product Name	Model Numbers	Firmware version
PcVue	PcVue	15.1.3

Device Profiles

Profile	Model Numbers
BACnet Operator Workstation (B-OWS)	All models

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-A	DS-WPM-A
	Change Of Value-A	DS-COV-A
	Change Of Value Property-A	DS-COVP-A
	Change Of Value Unsubscribed-A	DS-COVU-A
	View-A	DS-V-A
	Advanced View-A	DS-AV-A
	Modify-A	DS-M-A
Advanced Modify-A	DS-AM-A	

Alarm and Event Notification	Notification-A	AE-N-A
	Acknowledge-A	AE-ACK-A
	Alarm Summary-A	AE-ASUM-A
	Enrollment Summary-A	AE-ESUM-A
	Information-A	AE-INFO-A
	View Notifications-A	AE-VN-A
	Advanced View Notifications-A	AE-AVN-A
	View and Modify-A	AE-VM-A
	Advanced View and Modify-A	AE-AVM-A
	Alarm Summary View-A	AE-AS-A
	Event Log View-A	AE-ELV-A
	Event Log View and Modify-A	AE-ELVM-A

Scheduling	Advanced View and Modify-A	SCHED-AVM-A
	View and Modify-A	SCHED-VM-A
	Weekly Schedule-A	SCHED-WS-A

Trending	Viewing and Modifying Trends-A	T-VMT-A
	Automated Trend Retrieval-A	T-ATR-A
	Viewing and Modifying Multiple Values-A	T-VMMV-A
	Automated Multiple Value Retrieval-A	T-AMVR-A
	View-A	T-V-A
	Advanced View and Modify-A	T-AVM-A
	Archival-A	T-A-A

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-A	DM-DCC-A
	TimeSynchronization-A	DM-TS-A
	UTCTimeSynchronization-A	DM-UTC-A
	ReinitializeDevice-A	DM-RD-A
	Backup and Restore-A	DM-BR-A
	List Manipulation-A	DM-LM-A
	List Manipulation-B	DM-LM-B
	Object Creation and Deletion-A	DM-OCD-A
	Automatic Network Mapping-A	DM-ANM-A
	Automatic Device Mapping-A	DM-ADM-A
	Automatic Time Synchronization-A	DM-ATS-A
Manual Time Synchronization-A	DM-MTS-A	

Object Type Support

Device		
--------	--	--

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	BBMD Register as Foreign Device BACnet/IP, 'DIX' Ethernet

Character Set Support

ISO 10646 (UTF-8)
