

BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BACnet International website.

Listing Information (BTL-30528)

| Vendor | | Listing Status |
|---|--------------------------|----------------|
| Automated Logic Corporation 1150 Roberts Blvd Kennesaw, GA 30144 USA | | Listed Product |
| Test Requirements | BACnet Protocol Revision | Date Tested |
| Requirements as of December 2018 | Revision 14 (135-2012) | August 2019 |

| Product Name | Model Numbers | Version |
|--------------------------|---------------|-------------|
| OptiFlex™ BACnet Gateway | G5CE | 103.06.2045 |

Device Profiles

| Profile | Model Numbers |
|---|---------------|
| BACnet Building Controller (B-BC) | |
| BACnet Router (B-RTR) | All models |
| BACnet Broadcast Management Device (B-BBMD) | |

BIBBs Supported

| | ReadProperty-A | DS-RP-A |
|--------------|-------------------------|----------|
| | ReadProperty-B | DS-RP-B |
| | ReadPropertyMultiple-A | DS-RPM-A |
| | ReadPropertyMultiple-B | DS-RPM-B |
| Data Charing | WriteProperty-A | DS-WP-A |
| Data Sharing | WriteProperty-B | DS-WP-B |
| | WritePropertyMultiple-A | DS-WPM-A |
| | WritePropertyMultiple-B | DS-WPM-B |
| | Change Of Value-A | DS-COV-A |
| | Change Of Value-B | DS-COV-B |

| Alarm and Event | Notification Internal-B | AE-N-I-B |
|-------------------|---|------------|
| | Acknowledge-B | AE-ACK-B |
| Notification — | Alarm Summary-B | AE-ASUM-B |
| Notification | Enrollment Summary-B | AE-ESUM-B |
| | Information-B | AE-INFO-B |
| | | |
| Schoduling | Internal-B | SCHED-I-B |
| Scheduling | External-B | SCHED-E-B |
| | | |
| Tranding | Viewing and Modifying Trends Internal-B | T-VMT-I-B |
| Trending | Automated Trend Retrieval-B | T-ATR-B |
| | | |
| | Dynamic Device Binding-A | DM-DDB-A |
| | Dynamic Device Binding-B | DM-DDB-B |
| | Dynamic Object Binding-A | DM-DOB-A |
| | Dynamic Object Binding-B | DM-DOB-B |
| | DeviceCommunicationControl-B | DM-DCC-B |
| | TimeSynchronization-A | DM-TS-A |
| | TimeSynchronization-B | DM-TS-B |
| | UTCTimeSynchronization-A | DM-UTC-A |
| Device Management | UTCTimeSynchronization-B | DM-UTC-B |
| | ReinitializeDevice-B | DM-RD-B |
| | Backup and Restore-B | DM-BR-B |
| | Restart-B | DM-R-B |
| | List Manipulation-B | DM-LM-B |
| | Automatic Time Synchronization-A | DM-ATS-A |
| | Manual Time Synchronization-A | DM-MTS-A |
| | Router Configuration-B | NM-RC-B |
| | BBMD Configuration-B | NM-BBMDC-B |

Object Type Support

| Analog Input | Analog Output | Analog Value |
|--------------|-------------------|--------------------|
| Binary Input | Binary Output | Binary Value |
| Calendar | Device | File |
| Loop | Multi-State Value | Notification Class |
| Program | Schedule | Trend Log |

Data Link Layer Options

| Media | Options |
|---------------------|--|
| DACnet/ID (Anney I) | Register as Foreign Device |
| BACnet/IP (Annex J) | BACnet/IP, 'DIX' Ethernet |
| MS/TP Master | 9600, 19200, 38400, 76800, 57600, 115200 |
| Ethernet | ISO 8802-3, 10BASET |
| ARCNET | ARCNET, twisted pair bus |

Character Set Support

| ISO 10646 (UTF-8) | |
|-------------------|--|
| | |