



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information (BTL-30226)

Vendor Azbil Corporation 19F Tokyo Building 2-7-3 Marunouchi, Chiyoda-ku Tokyo 100-6419 Japan		Listing Status  Listed Product
Test Requirements Requirements as of November 2014	BACnet Protocol Revision Revision 12 (135-2010)	Date Tested December 2015

Product Name	Model Number(s)	Software Version
savic-net™	BS-700 XXXX <sup>1</sup> X <sup>2</sup> XX <sup>3</sup> X <sup>4</sup> X <sup>5</sup> X <sup>6</sup> X <sup>7</sup>  where XXXX <sup>1</sup> is BSST, CSST or HSST X <sup>2</sup> is C or R XX <sup>3</sup> is 02, 05 or 65 X <sup>4</sup> is 0, 1, 2 or 3 X <sup>5</sup> is 0, 1, 2, 3 or 4 X <sup>6</sup> is 0, 1 or none X <sup>7</sup> is 0, 1 or none	11.2

### Device Profiles

Profile	Model Numbers
BACnet Advanced Operator Workstation (B-AWS)	All models

### BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-A	DS-WPM-A
	COV-A	DS-COV-A
	View-A	DS-V-A

	Advanced View-A	DS-AV-A
	Modify-A	DS-M-A
	Advanced Modify-A	DS-AM-A

Alarm and Event Management	Alarm and Event-Notification-A	AE-N-A
	Alarm and Event-ACK-A	AE-ACK-A
	Alarm and Event-View Notifications-A	AE-VN-A
	Alarm and Event-Advanced View Notifications-A	AE-AVN-A
	Alarm and Event-View and Modify-A	AE-VM-A
	Alarm and Event-Advanced View and Modify-A	AE-AVM-A
	Alarm and Event-Alarm Summary View-A	AE-AS-A
	Alarm and Event-Alarm Summary-A	AE-ASUM-A
	Alarm and Event-Enrollment Summary-A	AE-ESUM-A
	Alarm and Event-Information-A	AE-INFO-A
	Alarm and Event-Event Log View-A	AE-ELV-A
Alarm and Event-Event Log View and Modify-A	AE-ELVM-A	

Scheduling	Scheduling-A	SCHED-A
	Scheduling-View and Modify-A	SCHED-VM-A
	Scheduling-Advanced View and Modify-A	SCHED-AVM-A

Trending	Trending-View-A	T-V-A
	Trending-Advanced View and Modify-A	T-AVM-A
	Trending-Automated Trend Retrieval-A	T-ATR-A
	Trending-Automated Multiple Value Retrieval-A	T-AMVR-A
	Trending-Archival-A	T-A-A

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	Automatic Device Mapping-A	DM-ADM-A
	Automatic Network Mapping-A	DM-ANM-A
	Time Synchronization-A	DM-TS-A
	UTC Time Synchronization-A	DM-UTC-A
	Manual Time Synchronization-A	DM-MTS-A
	Automatic Time Synchronization-A	DM-ATS-A
	Device Communication Control-A	DM-DCC-A
	Reinitialize Device-A	DM-RD-A
	Backup and Restore-A	DM-BR-A
	List Manipulation-A	DM-LM-A
	List Manipulation-B	DM-LM-B
	Object Creation and Deletion-A	DM-OCD-A

## Object Type Support

Device		
--------	--	--

## Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	Register as Foreign Device

## Character Set Support

ISO 10646 (UTF-8)
-------------------