



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.*

### Listing Information (BTL-30271)

Vendor		Listing Status
BELIMO Automation AG Brunnenbachstr. 1 8340 Hinwil Switzerland		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of November 2014	Revision 12 (135-2010)	August 2017

Product Name	Model Numbers	Software Version
Energy Valve (Europe/Asia)	EV $x^1$ R+BAC where $x^1$ is 015, 020, 025, 032, 040, 050 EV050R+BAC-N P $x^2$ W $x^3$ EV-BAC where $x^2$ is 6065, 6080, 6100, 6125, 6150, 6065, 6080, 6100, 6125 where $x^3$ is 800, 1100, 2000, 3100, 4500, 806, 1106, 2006, 3106 $x^4$ R24AX-EV+EV $x^5$ R, $x^4$ R24AX-EV+EV $x^5$ RV where $x^4$ is L, N, or S where $x^5$ is 015, 020, 025, 032, 040, 050 SR24AX-EV+EV050R-N, SR24AX-EV+EV050RV-N	3.02-0000

Energy Valve (Europe/Asia)	$x^6$ R24AX-EV+Px <sup>7</sup> W $x^8$ EV, $x^6$ R24AX-EV+Px <sup>7</sup> WV $x^8$ EV where $x^6$ is S or G where $x^7$ is 6065, 6080, 6100, 6125, 6150 where $x^8$ is 800, 1100, 2000, 3100, 4500 SRK24AX-EV+EV $x^9$ R where $x^9$ is 015, 020, 025, 032, 040, 050 SRK24AX-EV+EV050R-N	3.02-0000
----------------------------	--	-----------

## Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

## BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	COV-B	DS-COV-B

Device Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B

## Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Value	Device
Multi-State Input	Multi-State Output	Multi-State Value

## Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	Register as Foreign Device
MS/TP Master	9600, 19200, 38400, 76800, 115200

## Character Set Support

ISO 10646 (UTF-8)
-------------------