



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.

Listing Information (BTL-30308-2)

Vendor		Listing Status
BEST Co., Ltd. 53-28, Gapdong-ro 25beon-gil Yuseong-gu, Daejeon Republic of Korea		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of November 2014	Revision 14 (135-2012)	November 2017

Product Name	Model Numbers	Software Version
SMART IoT	SMART IoT	2.3 (BACnet SW 4.3.58.22.3)

Device Profiles

Profile	Model Numbers
BACnet Advanced Operator Workstation (B-AWS) BACnet Operator Workstation (B-OWS)	All models

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-A	DS-WPM-A
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
	View - A	DS-V-A
	Advanced View - A	DS-AV-A
	Modify - A	DS-M-A
Advanced Modify - A	DS-AM-A	

Alarm and Event Notification	Notification-A	AE-N-A
	ACK-A	AE-ACK-A
	Information-A	AE-INFO-A
	View Notifications - A	AE-VN-A
	Advanced View Notifications-A	AE-AVN-A
	View and Modify - A	AE-VM-A
	Advanced View and Modify - A	AE-AVM-A
	Alarm Summary View - A	AE-AS-A
	Event Log View - A	AE-ELV-A
	Event Log View and Modify - A	AE-ELVM-A

Scheduling	Advanced View and Modify-A	SCHED-AVM-A
	View and Modify-A	SCHED-VM-A
	Weekly Schedule-A	SCHED-WS-A

Trending	Automated Trend Retrieval-A	T-ATR-A
	Automated Multiple Value Retrieval-A	T-AMVR-A
	View-A	T-V-A
	Advanced View and Modify-A	T-AVM-A
	Archival-A	T-A-A

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-A	DM-DCC-A
	TimeSynchronization-A	DM-TS-A
	UTCTimeSynchronization-A	DM-UTC-A
	ReinitializeDevice-A	DM-RD-A
	Backup and Restore-A	DM-BR-A
	List Manipulation-A	DM-LM-A
	Object Creation and Deletion-A	DM-OCD-A
	Automatic Network Mapping-A	DM-ANM-A
	Automatic Device Mapping-A	DM-ADM-A
	Automatic Time Synchronization-A	DM-ATS-A
	Manual Time Synchronization-A	DM-MTS-A

Object Type SupportData Link Layer Options

Media	Options
BACnet/IP (Annex J)	BBMD, Register as Foreign Device
Ethernet	

Networking Options

Networking Functionality	Media
Router	BACnet/IP (Annex J), Ethernet
BBMD	BACnet/IP (Annex J), Ethernet

Character Set Support

ISO 10646 (UTF-8)
IBM/Microsoft DBCS
JIS X 0208
ISO 8859-1
ISO 10646 (UCS-4)
ISO 10646 (UCS2)