



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-31536)

Vendor		Listing Status
Caleffi S.p.A. S.R. 229, n. 25 28010 Fontaneto d'Agogna (NO) Italy		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of December 2024	Revision 19 (135-2016)	March 2026

Product Name	Model Numbers	Firmware version
LEGIOMIXevo 6003 Series	600301A, 600302A, 600303A, 600306A, 600308A, 600311A, 600312A, 600313A, 600336, 600338, 600353, 600354, 600356, 600356A, 600358, 600358A, 600363, 600364, 600373, 600374, 600383, 600384, 600393, 600394, F0007676, F0007683, 600316, 600318, 600351, 600361, 600371, 600381, 600391, F0007677, 600354A, 600354AF, NA600356A, 600356AF, 600359A, 600359AF, 600364A, 600364A 001, 600364AF, 600364AF 001 600366A, 600366A 001, 600366AF,	2.0.0

	600366AF 001, 600369A, 600369A 001, 600369AF, 600369AF 001, 600374A, 600374AF, 600376A, 600376AF, 600379A, 600379AF, 600384A, 600384AF, 600386A, 600386AF, 600389A, 600389AF, 600394A, 600394AF, 600396A, 600396AF, 600399A, 600399AF, 600366AFS, 600376AFS, 600386AFS, 600396AFS, 600360AFS, 600380AFS, 600366AFS 001, 600376AFS 001, 600386AFS 001, 600396AFS 001, 600360AFS 001, 600380AFS 001	
--	---	--

Device Profiles

Profile	Model Numbers
BACnet Smart Actuator (B-SA)	All models

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B

Device Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	ReinitializeDevice-B	DM-RD-B

Object Type Support

Analog Input	Analog Value	Binary Value
Characterstring Value	Device	Network Port

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	Register as Foreign Device BACnet/IP, 'DIX' Ethernet

Character Set Support

ISO 10646 (UTF-8)
