



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

# BACnet Testing Laboratories Product Listing

*BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.*

## Listing Information (BTL-31554)

Vendor		Listing Status
Computrols 2520 Belle Chasse Hwy Gretna, LA 70053 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of December 2024	Revision 18	March 2026

Product Name	Model Numbers	Firmware version
VAV-C	VAV-C	FW:4.3.25/ASV 25

## Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

## BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B

Device Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B

## Object Type Support

Analog Value	Binary Value	Device
File	Multi-State Value	Network Port

## Data Link Layer Options

Media	Options
MS/TP Manager	9600, 19200, 38400, 76800, 115200

## Character Set Support

ISO 10646 (UTF-8)
-------------------