



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.

Listing Information (BTL-30033)

Vendor ConneXSoft GmbH Lohenstrasse 4 82166 Graefelfing Germany		Listing Status Listed Product
Test Requirements Requirements as of July 2009	BACnet Protocol Revision Revision 7 (135-2008)	Date Tested June 2012

Product Name CXS BACnet DA Server	Model Number(s) 29-0027-1	Software Version 4.78
--------------------------------------	------------------------------	--------------------------

Device Profiles

Profile BACnet Operator Workstation (B-OWS)	Model Numbers All models
--	-----------------------------

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	WriteProperty-A	DS-WP-A
	WritePropertyMultiple-A	DS-WPM-A
	View-A	DS-V-A
	Modify-A	DS-M-A

Alarm and Event Management	Alarm and Event-Notification-A	AE-N-A
	Alarm and Event-ACK-A	AE-ACK-A
	Alarm and Event-View Notifications-A	AE-VN-A
	Alarm and Event-View and Modify-A	AE-VM-A
	Alarm and Event-Alarm Summary View-A	AE-AS-A

Scheduling	Scheduling-View and Modify-A	SCHED-VM-A
------------	------------------------------	------------

Trending	Trending-View-A	T-V-A
----------	-----------------	-------

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	Manual Time Synchronization-A	DM-MTS-A

Object Type Support

Device		
--------	--	--

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	Register as Foreign Device

Character Set Support

ANSI X3.4
