



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Labs Product Listing

This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.

Listing Information (BTL-25110)

Vendor		Listing Status
Continental Control Systems, LLC 2150 Miller Drive, Suite A Longmont, CO 80501 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of August 2012	Revision 10	May 2013

Product Name	Model Number	Software Version
WattNode BACnet	WNC-3Y-208-BN, RWNC-3Y-208-BN, WNC-3Y-400-BN, RWNC-3Y-400-BN, WNC-3Y-480-BN, RWNC-3Y-480-BN, WNC-3Y-600-BN, RWNC-3Y-600-BN, WNC-3D-240-BN, RWNC-3D-240-BN, WNC-3D-400-BN, RWNC-3D-400-BN, WNC-3D-480-BN, RWNC-3D-480-BN	1.14

Device Profiles

Profile	Model Numbers
BACnet Smart Sensor (B-SS)	All models

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	ReinitializeDevice-B	DM-RD-B

Object Type Support

Analog Input	Analog Value	Binary Value
Device	File	Multi-state Value

Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800

Character Set Support

UTF-8 / ANSI X3.4
