



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BACnet International website.

Listing Information (BTL-30496)

Vendor		Listing Status
CoolAutomation Ltd. Mivtahim, 2 Petah-Tikva Israel		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of December 2018	Revision 14 (135-2012)	August 2019

Product Name	Model Numbers	Software Version
CoolMasterNet	7.9	1.1

Device Profiles

Profile	Model Numbers
BACnet General (B-GENERAL)	All models

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B

Device Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B

Object Type Support

Analog Input	Analog Value	Binary Input
Binary Value	Characterstring Value	Device
Integer Value	Multi-State Value	Positive Integer Value

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	Register as Foreign Device
MS/TP Master	9600, 38400

Character Set Support

ISO 10646 (UTF-8)
