



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BACnet International website.*

### Listing Information (BTL-30523)

Vendor		Listing Status
Crestron Electronics, Inc. 15 Volvo Drive Rockleigh, NJ 07647 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of October 2018	Revision 15	October 2019

Product Name	Model Numbers	Firmware version
Crestron 3-Series Control Systems	AV3, PRO3, RMC3, ZUM-FLOOR-HUB, CP3x <sup>1</sup> , DIN-AP3x <sup>2</sup> , DMPS3-x <sup>3</sup> -C, DMPS3-4K-x <sup>4</sup> -Cx <sup>5</sup> , MPC3-x <sup>6</sup>  Where: x <sup>1</sup> is null, -R, or N x <sup>2</sup> is null or MEX x <sup>3</sup> is 200 or 300 x <sup>4</sup> is 100, 150, 250, 350, or 50 x <sup>5</sup> is null or -AIRMEDIA x <sup>6</sup> is 101, 102, 201, 302	PUF 1.601.0050  BACnet.exe: 1.0.6974.20566

### Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

## BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	Change Of Value-A	DS-COV-A
	Change Of Value-B	DS-COV-B

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B

## Object Type Support

Analog Input	Analog Value	Binary Input
Binary Value	Device	Multi-State Input
Multi-State Value		

## Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	BBMD, Register as Foreign Device

## Networking Options

Networking Functionality	Media
BBMD	BACnet/IP (Annex J)

## Character Set Support

ISO 10646 (UTF-8)
-------------------