



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

## BACnet Testing Laboratories Product Listing

*BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.*

### Listing Information (BTL-31515)

Vendor		Listing Status
DAIKIN INDUSTRIES, LTD. 1-13-1 Umeda, Kita-ku, Osaka Umeda Twin Towers South Osaka City, Osaka Japan		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of December 2024	Revision 19 (135-2016)	February 2026

Product Name	Model Numbers	Firmware version
DK-CONNECT edge, Daikin HERO Pro Edge	DGE601A1, DGE601B1, DGE601A71, DGE601B71	Firmware Revision: 000.001 Application Software Version: 2.4.50

### Device Profiles

Profile	Model Numbers
BACnet Gateway (B-GW) BACnet General (B-GENERAL)	All models

### BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-B	DS-COV-B

Device Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Router Configuration-B	NM-RC-B
	Foreign Device Registration-A	NM-FDR-A
	Virtual Network-B	GW-VN-B

## Object Type Support

Analog Input	Analog Value	Binary Input
Binary Output	Binary Value	Device
Multi-State Input	Multi-State Output	Multi-State Value
Network Port		

## Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	Register as Foreign Device BACnet/IP, 'DIX' Ethernet
Virtual	

## Character Set Support

ISO 10646 (UTF-8)
-------------------