



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

## BACnet Testing Laboratories Product Listing

*BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.*

### Listing Information (BTL-31516)

Vendor		Listing Status
DAIKIN Industries, Ltd. 1000-2 Okamoto-cho Kusatsu, Shiga Japan		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of February 2021	Revision 14 (135-2012)	June 2021

Product Name	Model Numbers	Firmware version
D3-NET/BACnet MS/TP Communication adaptor	DTA118A71	Application Software version: SP3000_066 Firmware version: SP2143G030
	DTA118A72	Application Software version: SP3000A068 Firmware version: SP2143G030
	DTA118A73	Application Software version: SP3000A072 Firmware version: SP2143G030

### Device Profiles

Profile	Model Numbers
BACnet Gateway (B-GW) BACnet General (B-GENERAL)	All models

## BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B

Device Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	Router Configuration-B	NM-RC-B
	Virtual Network-B	GW-VN-B

## Object Type Support

Analog Input	Analog Value	Binary Input
Binary Value	Device	Multi-State Input
Multi-State Value		

## Data Link Layer Options

Media	Options
MS/TP Master	9600, 19200, 38400, 76800

## Character Set Support

ISO 10646 (UTF-8)
-------------------