



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Labs Product Listing

*This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor Delta Controls Inc. 17850 56 <sup>th</sup> Ave Surrey, BC, V3S 1C7 Canada		Listing Status  Listed Product
Test Requirements Requirements as of November 2014	BACnet Protocol Revision Revision 12	Date Tested August 2015

Product Name	Model Number	Software Version
enteliZONE	eZFC-424R4-24 eZFCP-424R4-24 eZV-440 eZVP-440 eZ-440R4-230 eZP-440R4-230	3.40-eZ2.1

### Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

### BIBBs Supported

Data Sharing	ReadProperty-A <sup>1</sup>	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	COV-B	DS-COV-B
	COVU-B	DS-COVU-B

<sup>1</sup> Not present in the eZFC-424R4-24.

Alarm and Event Management	Alarm and Event-Notification Internal-B	AE-N-I-B
	Alarm and Event-Information-B	AE-INFO-B

Scheduling	Weekly Schedule-Internal-B	SCHED-WS-I-B
------------	----------------------------	--------------

Trending	Viewing and Modifying Trends-Internal-B	T-VMT-I-B
----------	---	-----------

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Object Creation and Deletion-B	DM-OC-D-B

## Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Device	Event Enrollment <sup>2</sup>	File
Loop	Multi-State Value	Notification Class
Program <sup>2</sup>	Schedule	Trend Log

<sup>2</sup> Not present in the eZFC-424R4-24, eZ-440R4-230, or eZV-440.

## Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800

## Character Set Support

ISO 10646 (UTF-8)
-------------------