



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.

Listing Information (BTL-30084)

| | | |
|--|--|--------------------------------------|
| Vendor Delta Controls 17850 56 th Ave Surrey, BC Canada | | Listing Status Listed Product |
| Test Requirements Requirements as of November 2014 | BACnet Protocol Revision Revision 14 (135-2012) | Date Tested August 2016 |

| | | |
|-------------------------------|--------------------------|-------------------------------|
| Product Name enteliWEB 4.1 | Model Number eWEB-4.1 | Software Version 4.1.0.738 |
|-------------------------------|--------------------------|-------------------------------|

Device Profiles

| | |
|---|---------------------------|
| Profile BACnet Advanced Operator Workstation (B-AWS) | Model Numbers eWEB-4.1 |
|---|---------------------------|

BIBBs Supported

| | | |
|--------------|-------------------------|----------|
| Data Sharing | ReadProperty-A | DS-RP-A |
| | ReadProperty-B | DS-RP-B |
| | ReadPropertyMultiple-A | DS-RPM-A |
| | ReadPropertyMultiple-B | DS-RPM-B |
| | WriteProperty-A | DS-WP-A |
| | WriteProperty-B | DS-WP-B |
| | WritePropertyMultiple-A | DS-WPM-A |
| | WritePropertyMultiple-B | DS-WPM-B |
| | View-A | DS-V-A |
| | Advanced View-A | DS-AV-A |
| | Modify-A | DS-M-A |
| | Advanced Modify-A | DS-AM-A |

| | | |
|-------------------------------|-----------------------------|-----------|
| Alarm and Event Notification | Notification-A | AE-N-A |
| | ACK-A | AE-ACK-A |
| | View and Modify-A | AE-VM-A |
| | Advanced View and Modify-A | AE-AVM-A |
| | Event Log-View-A | AE-ELV-A |
| | Event Log-View and Modify-A | AE-ELVM-A |
| | Alarm Summary View-A | AE-AS-A |
| | View Notifications-A | AE-VN-A |
| Advanced View Notifications-A | AE-AVN-A | |

| | | |
|------------|----------------------------|-------------|
| Scheduling | Advanced View and Modify-A | SCHED-AVM-A |
| | View and Modify-A | SCHED-VM-A |
| | Weekly Schedule-A | SCHED-WS-A |

| | | |
|----------|----------------------------|---------|
| Trending | Trending-View-A | T-V-A |
| | Advanced View and Modify-A | T-AVM-A |

| | | |
|-------------------------------|----------------------------------|----------|
| Device and Network Management | Dynamic Device Binding-A | DM-DDB-A |
| | Dynamic Device Binding-B | DM-DDB-B |
| | Dynamic Object Binding-B | DM-DOB-B |
| | DeviceCommunicationControl-A | DM-DCC-A |
| | DeviceCommunicationControl-B | DM-DCC-B |
| | Automatic Network Mapping-A | DM-ANM-A |
| | Automatic Device Mapping-A | DM-ADM-A |
| | Time Synchronization-A | DM-TS-A |
| | UTC Time Synchronization-A | DM-UTC-A |
| | Manual Time Synchronization-A | DM-MTS-A |
| | Automatic Time Synchronization-A | DM-ATS-A |
| | ReinitializeDevice-A | DM-RD-A |
| | Backup and Restore-A | DM-BR-A |
| | Object Creation and Deletion-A | DM-OCD-A |
| | Object Creation and Deletion-B | DM-OCD-B |
| List Manipulation-B | DM-LM-B | |

Object Type Support

| | | |
|--------|------|--|
| Device | File | |
|--------|------|--|

Data Link Layer Options

| Media | Options |
|---------------------|----------------------------|
| BACnet IP (Annex J) | Register as Foreign Device |
| Ethernet | |

Character Set Support

| |
|-------------------|
| ISO 10646 (UTF-8) |
|-------------------|