



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BACnet International website.

Listing Information (BTL-30083)

Vendor		Listing Status
Delta Controls 17850 56 th Ave Surrey, BC Canada		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of August 2012	Revision 12 (135-2010)	June 2014

Product Name	Model Number	Software Version
enteliWEB 2.2	eWEB-2.2	2.2.320

Device Profiles

Profile	Model Numbers
BACnet Operator Workstation (B-OWS)	eWEB

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-A	DS-WPM-A
	WritePropertyMultiple-B	DS-WPM-B
	View-A	DS-V-A
	Advanced View-A	DS-AV-A
	Modify-A	DS-M-A

Alarm and Event Notification	Notification-A	AE-N-A
	ACK-A	AE-ACK-A
	View and Modify-A	AE-VM-A
	Event Log-View-A	AE-ELV-A
	Event Log-View and Modify-A	AE-ELVM-A
	Alarm Summary-A	AE-ASUM-A
	Enrollment Summary-A	AE-ESUM-A
	Information-A	AE-INFO-A
	Alarm Summary View-A	AE-AS-A
	View Notifications-A	AE-VN-A
Advanced View Notifications-A	AE-AVN-A	

Scheduling	Scheduling-A	SCHED-A
	Scheduling-View and Modify-A	SCHED-VM-A
	Weekly Schedule-A	SCHED-WS-A

Trending	Trending-View-A	T-V-A
	Viewing and Modifying Trends-A	T-VMT-A
	Viewing and Modifying Multiple Value-A	T-VMMV-A

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	Automatic Network Mapping-A	DM-ANM-A
	Automatic Device Mapping-A	DM-ADM-A
	Time Synchronization-A	DM-TS-A
	UTC Time Synchronization-A	DM-UTC-A
	Manual Time Synchronization-A	DM-MTS-A
	Restart-B	DM-R-B
	Object Creation and Deletion-B	DM-OCD-B
List Manipulation-B	DM-LM-B	

Object Type Support

Device	File
--------	------

Data Link Layer Options

Media	Options
BACnet IP (Annex J)	Register as Foreign Device
Ethernet	

Character Set Support

ISO 10646 (UTF-8)
