



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BACnet International website.

Listing Information (BTL-30357)

Vendor		Listing Status
Delta Controls Inc. 17850 56th Avenue Surrey, BC Canada V3S 1C7		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of May 2018	Revision 12 (135-2010)	September 2018

Product Name	Model Numbers	Software Version
enteliZONE	eZNTW-Enx ¹ x ² where x ¹ is 868 or 902 x ² is C, HM, CHM or omitted eZNT-Tx ³ x ⁴ where x ³ is 100, 304 or 331 x ⁴ is C, HM, CHM or omitted	eZONE V3.40-eZ3.1

Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models
BACnet Gateway (B-GW)	eZNTW models

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	COV-B	DS-COV-B
	COV-Unsubscribed-B	DS-COVU-B

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	Information-B	AE-INFO-B

Scheduling	Weekly Schedule Internal-B	SCHED-WS-I-B
------------	----------------------------	--------------

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
----------	---	-----------

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Object Creation and Deletion-B	DM-OCD-B

Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Device	Event Enrollment	File
Loop Object	Multi-State Value	Notification Class
Program	Schedule	Trend Log

Data Link Layer Options

Media	Options
MS/TP Master	9600, 19200, 38400, 76800

Character Set Support

ISO 10646 (UTF-8)
