



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.

Listing Information (BTL-30263)

Vendor		Listing Status
DEOS AG Birkenallee 76 48432 Rheine Germany		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of November 2014	Revision 14 (135-2012)	December 2017

Product Name	Model Numbers	Software Version
OPENweb	DS-OWB	9.0.10 (BACnet FW: 2.1.5)

Device Profiles

Profile	Model Numbers
BACnet Advanced Operator Workstation (B-AWS)	All models

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-A	DS-WPM-A
	COV-A	DS-COV-A
	View - A	DS-V-A
	Advanced View - A	DS-AV-A
	Modify - A	DS-M-A
	Advanced Modify - A	DS-AM-A

Alarm and Event Notification	Notification-A	AE-N-A
	ACK-A	AE-ACK-A
	Alarm Summary-A	AE-ASUM-A
	Enrollment Summary-A	AE-ESUM-A
	Information-A	AE-INFO-A
	View Notifications - A	AE-VN-A
	Advanced View Notifications-A	AE-AVN-A
	View and Modify - A	AE-VM-A
	Advanced View and Modify - A	AE-AVM-A
	Alarm Summary View - A	AE-AS-A
	Event Log View - A	AE-ELV-A
Event Log View and Modify - A	AE-ELVM-A	

Scheduling	Advanced View and Modify-A	SCHED-AVM-A
	View and Modify-A	SCHED-VM-A
	Weekly Schedule-A	SCHED-WS-A

Trending	Viewing and Modifying Trends-A	T-VMT-A
	Automated Trend Retrieval-A	T-ATR-A
	Viewing and Modifying Multiple Values-A	T-VMMV-A
	Automated Multiple Value Retrieval-A	T-AMVR-A
	View-A	T-V-A
	Advanced View and Modify-A	T-AVM-A
Archival-A	T-A-A	

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-A	DM-DOB-A
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-A	DM-DCC-A
	TimeSynchronization-A	DM-TS-A
	UTCTimeSynchronization-A	DM-UTC-A
	ReinitializeDevice-A	DM-RD-A
	Backup and Restore-A	DM-BR-A
	Restart-A	DM-R-A
	Restart-B	DM-R-B
	List Manipulation-A	DM-LM-A
	List Manipulation-B	DM-LM-B
	Object Creation and Deletion-A	DM-OCD-A
	Automatic Network Mapping-A	DM-ANM-A
	Automatic Device Mapping-A	DM-ADM-A
	Automatic Time Synchronization-A	DM-ATS-A
Manual Time Synchronization-A	DM-MTS-A	

Object Type Support

Device		
--------	--	--

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	Register as Foreign Device

Networking Options

Networking Functionality	Media
BBMD	BACnet/IP (Annex J)

Character Set Support

ISO 10646 (UTF-8) IBM/Microsoft DBCS ISO 8859-1 ISO 10646 (UCS-2) ISO 10646 (UCS-4) JIS X 0208
