

BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-31024)

| Vendor | | Listing Status |
|---|--------------------------|----------------|
| Distech Controls, Inc. 4205 Place de Java Brossard, Quebec Canada, J4Y 0C4 | | Listed Product |
| Test Requirements | BACnet Protocol Revision | Date Tested |
| Requirements as of January 2020 | Revision 15 | November 2020 |

| Product Name | Model Numbers | Version |
|----------------|---|----------------|
| ECB ASC Series | ECB-103, ECB-203, ECB-253, ECB-VAV, ECB-VAV-N, ECB-VAVS | A:2.17.20287.2 |
| ECB ASC Series | ECB-PTU-107, ECB-PTU-207, ECB-PTU-208, ECB-PTU-307, ECB-PTU-308 | A:2.7.20287.2 |

Device Profiles

| Profile | Model Numbers |
|--|---------------|
| BACnet Application Specific Controller (B-ASC) | All models |

BIBBs Supported

| Data Sharing | ReadProperty-A | DS-RP-A |
|--------------|--------------------------------|-----------|
| | ReadProperty-B | DS-RP-B |
| | ReadPropertyMultiple-A | DS-RPM-A |
| | ReadPropertyMultiple-B | DS-RPM-B |
| | WriteProperty-A | DS-WP-A |
| | WriteProperty-B | DS-WP-B |
| | WritePropertyMultiple-A | DS-WPM-A |
| | WritePropertyMultiple-B | DS-WPM-B |
| | Change Of Value-A | DS-COV-A |
| | Change Of Value-B | DS-COV-B |
| | Change Of Value Unsubscribed-A | DS-COVU-A |
| | Change Of Value Unsubscribed-B | DS-COVU-B |

| Scheduling | Internal-B | SCHED-I-B |
|-------------------|-------------------------------|-----------|
| | | |
| | Dynamic Device Binding-A | DM-DDB-A |
| Device Management | Dynamic Device Binding-B | DM-DDB-B |
| | Dynamic Object Binding-B | DM-DOB-B |
| | DeviceCommunicationControl-B | DM-DCC-B |
| | TimeSynchronization-B | DM-TS-B |
| | UTCTimeSynchronization-B | DM-UTC-B |
| | ReinitializeDevice-B | DM-RD-B |
| | Manual Time Synchronization-A | DM-MTS-A |

Object Type Support

| Analog Input | Analog Output | Analog Value |
|--------------|-------------------|-------------------|
| Binary Input | Binary Output | Binary Value |
| Calendar | Device | File |
| Loop | Multi-State Input | Multi-State Value |
| Program | Schedule | |

Data Link Layer Options

| Media | Options |
|--------------|---------------------------|
| MS/TP Master | 9600, 19200, 38400, 76800 |

Character Set Support

| Design of the second | |
|---|--|
| ISO 10646 (UTF-8) | |
| | |