



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BACnet International website.

Listing Information (BTL-30229)

Vendor		Listing Status
Distech Controls, Inc. 4205 place de Java Brossard, Quebec Canada, J4Y 0C4		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of August 2012	Revision 9	December 2013

Product Name	Model Number(s)	Software Version
ECB-VAV Series	ECB-VAV ECB-VAV-N	Firmware Revision: 1.2.13337.1 Application Software Version: 2.14.17052.2
ECB-VAVS Series	ECB-VAVS ECB-VAVS-O ECB-VVTS	Firmware Revision: 1.2.13337.1 Application Software Version: 2.13.16138.1
ECB-103	ECB-103	Firmware Revision: 1.2.13337.1 Application Software Version: 2.13.16313.1
ECB-203 Series	ECB-203, ECB-253	Firmware Revision: 1.2.13337.1 Application Software Version: 2.13.16138.1

Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WritePropertyMultiple-A	DS-WPM-A
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
	COV-B	DS-COV-B

Scheduling	Scheduling Internal-B	SCHED-I-B
------------	-----------------------	-----------

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	ReinitializeDevice-B	DM-RD-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B

Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Calendar	Device	File
Loop	Multi-state Input	Multi-state Value
Program	Schedule	

Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800

Character Set Support

ANSI X3.4
