



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-30654)

Vendor		Listing Status
Engineered Air 1401 Hastings Cres. SE Calgary Alberta Canada, T2G 4C8		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of January 2020	Revision 14 (135-2012)	August 2020

Product Name	Model Numbers	Firmware version
CenCon	-	2.0.0

Device Profiles

Profile	Model Numbers
BACnet Smart Actuator (B-SA) BACnet Gateway (B-GW)	All models

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B

Device Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	Virtual Network-B	GW-VN-B

Object Type Support

Analog Input	Analog Output	Binary Input
Binary Output	Device	

Data Link Layer Options

Media	Options
MS/TP Master	9600, 19200, 38400
BACnet/IP (Annex J)	BACnet/IP, 'DIX' Ethernet

Character Set Support

ISO 10646 (UTF-8)
