



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor		Listing Status
evon GmbH Frank-Stronach-Straße 8 8200 Gleisdorf, Austria		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of August 2012	Revision 12	January 2015

Product Name	Model Number(s)	Software Version
evon Controller	ec6915, ec6930, ec6910	2

### Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC)	All models

### BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	WriteProperty-A	DS-WP-A
	ReadProperty-B	DS-RP-B
	WriteProperty-B	DS-WP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
COV-B	DS-COV-B	

Alarm and Event Management	Alarm and Event-Notification Internal-B	AE-N-I-B
	Alarm and Event-ACK-B	AE-ACK-B
	Alarm and Event-Alarm Summary-B	AE-ASUM-B
	Alarm and Event-Enrollment Summary-B	AE-ESUM-B
	Alarm and Event-Information-B	AE-INFO-B

Scheduling	Scheduling Internal-B	SCHED-I-B
	Scheduling External-B	SCHED-E-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Viewing and Modifying Trends External-B	T-VMT-E-B
	Automated Trend Retrieval-B	T-ATR-B

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
Backup and Restore-B	DM-BR-B	

### Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Calendar	Device	File
Multi-state Input	Multi-state Output	Multi-state Value
Notification Class	Schedule	Trend Log

### Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	Register as a Foreign Device

### Character Set Support

ISO 10646 (UTF-8) ISO 8859-1
---------------------------------