

BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing LaboratoriesProduct Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-31014)

Vendor		Listing Status
GD Midea Heating & Ventilating Equip Midea Global Innovation Center, Indus Beijiao Town Shunde, Foshan, Guang China	try Road	Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of January 2022	Revision 15	March 2023

Product Name	Model Numbers	Firmware version
KONG M0 series	MKG41-BTW23 (DDC M0) MKG42-BTW23 (WU Controller) MKG43-Y23P (Plant Controller) MKG43-Y23M (Mini Controller) MKG43-BTW23(1024) (Edge Controller S) MKG43-BTW23(2048) (Edge Controller M) MKG43-BTW23(10000) (Edge Controller L) MKG45-BTW23 (Space Controller) MDV8-GW3-IMMProII-M04G (IMMPRO II Controller)	1.2.26.20230320

Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC)	All models

BIBBs Supported

	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
Data Charina	WriteProperty-B	DS-WP-B
Data Sharing	WritePropertyMultiple-A	DS-WPM-A
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-A	DS-COV-A
	Change Of Value-B	DS-COV-B
	Change Of Value Unsubscribed-A	DS-COVU-A
	Change Of Value Unsubscribed-B	DS-COVU-B

Alarm and Event	Notification Internal-B	AE-N-I-B
Alarm and Event Notification	Acknowledge-B	AE-ACK-B
Notification	Information-B	AE-INFO-B

Scheduling	Internal-B	SCHED-I-B
Scheduling	External-B	SCHED-E-B

Tranding	Viewing and Modifying Trends Internal-B	T-VMT-I-B
rrending	Automated Trend Retrieval-B	T-ATR-B

	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
Device Management	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B

Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Calendar	Device	Event Enrollment
File	Multi-State Input	Multi-State Output
Multi-State Value	Notification Class	Schedule
Trend Log		

Data Link Layer Options

Media	Options
DACnot/ID (Annoy I)	BBMD
BACnet/IP (Annex J)	BACnet/IP, 'DIX' Ethernet

Character Set Support

ISO 10646 (UTF-8)
